

2022 Consumer Confidence Report

Water System Name: MORNING STAR PKG. CO.-WMS.

Report Date: April 2023

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2022.

Este informe contiene información muy importante sobre su agua potable. Tradúzcalo ó hable con alguien que lo entienda bien.

Type of water source(s) in use: According to SWRCB records, this Source is Groundwater. This Assessment was done using the Default Groundwater System Method.

Your water comes from 3 source(s): WELL 01 - Raw, WELL 02 and WELL 03

Opportunities for public participation in decisions that affect drinking water quality: Regularly-scheduled water board or city/county council meetings currently are not being held. However, The Morning Star Packing Co. includes any and all CCR documents in their annual orientation packets that are distributed to all colleagues pre-season.

For more information about this report, or any questions relating to your drinking water, please call Tod Harter, 209-829-5002 or visit our website at www.morningstarco.com.

TERMS USED IN THIS REPORT

Maximum Contaminant Level (MCL): The highest level of contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).

Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Primary Drinking Water Standards (PDWS): MCLs and MRDLs for the contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

Secondary Drinking Water Standards (SDWS): MCLs for the contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Regulatory Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

Level 1 Assessment: A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment: A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

ND: not detectable at testing limit

mg/L: milligrams per liter or parts per million (ppm)

ug/L: micrograms per liter or parts per billion (ppb)

pCi/L: picocuries per liter (a measure of radiation)

NTU: Nephelometric Turbidity Units

umhos/cm: micro mhos per centimeter

The sources of drinking water: (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- *Radioactive contaminants*, that can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the USEPA and the State Water Resource Control Board (State Water Board) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. State Water Board regulations also establish limits for contaminants in bottled water that provide the same protection for public health.

Tables 1, 2, 3, 4, 5, 6, 7 and 8 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Water Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old.

Any violation of MCL, AL or MRDL is highlighted. Additional information regarding the violation is provided later in this report.

Table 1 - SAMPLING RESULTS SHOWING THE DETECTION OF COLIFORM BACTERIA

Microbiological Contaminants (complete if bacteria detected)	Highest No. of Detections	No. of Months in Violation	MCL	MCLG	Typical Sources of Contaminant
Total Coliform Bacteria	1/year (2022)	0	no more than 1 positive monthly sample	0	Naturally present in the environment.

Table 2 - SAMPLING RESULTS FOR SODIUM AND HARDNESS

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Sources of Contaminant
Sodium (mg/L)	(2017 - 2022)	75	66 - 92	none	none	Salt present in the water and is generally naturally occurring
Hardness (mg/L)	(2017 - 2022)	221	210 - 239	none	none	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring

Table 3 - DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Sources of Contaminant
Arsenic (ug/L)	(2019 - 2022)	2	ND - 4	10	0.004	Erosion of natural deposits; runoff from orchards, glass and electronics production wastes
Fluoride (mg/L)	(2017 - 2022)	0.3	0.2 - 0.3	2	1	Erosion of natural deposits; water additive that promotes strong teeth; discharge from fertilizer and aluminum factories.

Nitrate as N (mg/L)	(2021 - 2022)	0.8	ND - 1.1	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Nitrate + Nitrite as N (mg/L)	(2017)	ND	ND - 0.5	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Gross Alpha (pCi/L)	(2018)	2.76	1.52 - 3.99	15	(0)	Erosion of natural deposits.

Table 4 - DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Sources of Contaminant
Chloride (mg/L)	(2017 - 2022)	53	41 - 75	500	n/a	Runoff/leaching from natural deposits; seawater influence
Iron (ug/L)	(2017 - 2022)	393	ND - 1210	300	n/a	Leaching from natural deposits; Industrial wastes
Manganese (ug/L)	(2017 - 2022)	20	ND - 50	50	n/a	Leaching from natural deposits
Specific Conductance (umhos/cm)	(2017 - 2022)	738	665 - 858	1600	n/a	Substances that form ions when in water; seawater influence
Sulfate (mg/L)	(2017 - 2022)	74.6	65.2 - 93.9	500	n/a	Runoff/leaching from natural deposits; industrial wastes
Total Dissolved Solids (mg/L)	(2017 - 2022)	453	410 - 520	1000	n/a	Runoff/leaching from natural deposits
Turbidity (NTU)	(2017)	7.7	0.3 - 15.1	5	n/a	Soil runoff

Table 5 - DETECTION OF UNREGULATED CONTAMINANTS

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	Notification Level	Typical Sources of Contaminant
Boron (mg/L)	(2017 - 2022)	0.3	0.2 - 0.3	1	Boron exposures resulted in decreased fetal weight (developmental effects) in newborn rats.
Manganese (ug/L)	(2022)	27	ND - 50	n/a	n/a

Table 6 - ADDITIONAL DETECTIONS

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	Notification Level	Typical Sources of Contaminant
Calcium (mg/L)	(2017 - 2022)	46	39 - 48	n/a	n/a
Magnesium (mg/L)	(2017 - 2022)	26	22 - 29	n/a	n/a
pH (units)	(2017 - 2022)	7.67	7.4 - 8.1	n/a	n/a
Alkalinity (mg/L)	(2017 - 2022)	228	220 - 240	n/a	n/a
Aggressiveness Index	(2017 - 2022)	12.1	11.9 - 12.5	n/a	n/a
Langelier Index	(2017 - 2022)	0.21	-0.01 - 0.6	n/a	n/a

Table 7 - DETECTION OF DISINFECTANT/DISINFECTANT BYPRODUCT RULE

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL (MRDL)	PHG (MCLG)	Violation	Typical Sources of Contaminant
Haloacetic Acids (five) (ug/L)	(2022)	1	n/a	60	n/a	No	By-product of drinking water disinfection

Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead Specific Language for Community Water Systems: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with the service lines and home plumbing. *The Morning Star Packing Company-DW* is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/lead>.

Summary Information for Violation of a MCL, MRDL, AL, TT, or Monitoring and Reporting Requirement

VIOLATION OF A MCL,MRDL,AL,TT, OR MONITORING AND REPORTING REQUIREMENT				
Violation	Explanation	Duration	Actions Taken To Correct the Violation	Health Effects Language
Total Coliform Bacteria				Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially harmful, waterborne pathogens may be present or that a potential pathway exists through which contamination may enter the drinking water distribution system. We found coliforms indicating the need to look for potential problems in water treatment or distribution. When this occurs, we are required to conduct assessment(s) to identify problems and to correct any problems that were found during these assessments.

Iron				Iron was found at levels that exceed the secondary MCL. The Iron MCL was set to protect you against unpleasant aesthetic affects such as color, taste, odor and the staining of plumbing fixtures (e.g., tubs and sinks), and clothing while washing. Violating this MCL does not pose a risk to public health.
Manganese				Manganese was found at levels that exceed the secondary MCL. The Manganese MCL was set to protect you against unpleasant aesthetic affects such as color, taste, odor and the staining of plumbing fixtures (e.g., tubs and sinks), and clothing while washing. Violating this MCL does not pose a risk to public health.
Turbidity				Turbidity is Secondary Drinking Water Standards and has found no health effects. However, high levels of turbidity can interfere with disinfection and provide a medium for microbial growth. Turbidity may indicate the presence of disease-causing organisms. These organisms include bacteria, viruses, and parasites that can cause symptoms such as nausea, cramps, diarrhea and associated headaches.
No.21-22N-017	Failure to collect all repeat samples in April 2022 according to the approved BSSP following a total coliform-positive	30-days	MSPC to submit Level 1 Assessment	
No.21-23N-005	Failure to collect and report monthly raw bacteriological sample from Well #2 in the month of December 2022 following a positive total coliform result in October 2022	90-days	The raw unchlorinated water at Well #2 was monitored monthly	

2022 Consumer Confidence Report

Drinking Water Assessment Information

Assessment Information

A source water assessment was conducted for the WELL 01 - RAW and WELL 02 of the MORNING STAR PKG. CO.-WMS. water system in April, 2003.

WELL 01 - Raw - is considered most vulnerable to the following activities not associated with any detected contaminants:

Chemical/petroleum processing/storage

WELL 02 - is considered most vulnerable to the following activities not associated with any detected contaminants:

Chemical/petroleum processing/storage

WELL 03 - does not have a completed assessment on file.

Discussion of Vulnerability

Well 01 - There have been no contaminants detected in the water supply, however the source is still considered vulnerable to activities located near the drinking water source.

Well 02 - There have been no contaminants detected in the water supply, however the source is still considered vulnerable to

activities located near the drinking water source.

Well 03 - Assessment summaries are not available for some sources. This is because:

☐ The Assessment has not been completed. Contact the local Department of Health Services (DHS) Drinking Water field office or the water system to find out when the Assessment is scheduled to be done.

☐ The source is not active. It may be out of service, or new and not yet in service.

☐ The Assessment was not submitted electronically. The site used to obtain Assessments only provides access to Assessment summaries submitted electronically.

Acquiring Information

A copy of the complete assessment may be viewed at:

Redding Field Operations Office

364 Knollcrest Drive, Suite 101

Redding, CA 96002

You may request a summary of the assessment be sent to you by contacting:

Reese Crenshaw

District Engineer

530-224-4861

530-224-4844 (fax)

Reese.Crenshaw@waterboards.ca.gov

For more info you may visit https://www.waterboards.ca.gov/drinking_water/certlic/drinkingwater/DWSAP.html or contact the health department in the county to which the water system belongs as indicated on this following link: https://www.waterboards.ca.gov/drinking_water/programs/documents/ddwem/DDWdistrictofficesmap.pdf

The Morning Star Packing Company-DW

Analytical Results By FGL - 2022

MICROBIOLOGICAL CONTAMINANTS									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Total Coliform Bacteria			0	5%	n/a			0	-
Laboratory	CH 2272846-2					2022-04-29	<1.0		
Shipping	CH 2279754-1					2022-11-17	Absent		
Shipping	CH 2277515-1					2022-09-01	Absent		
Shipping	CH 2275672-1					2022-07-14	Absent		
Shipping	CH 2273740-1					2022-05-26	Absent		
Shipping	CH 2272813-1					2022-04-27	Present		
Shipping	CH 2271600-1					2022-03-10	Absent		
Shipping	CH 2270153-1					2022-01-06	Absent		
Shipping Office	CH 2272846-1					2022-04-29	<1.0		
Truck Shop	CH 2290288-1					2022-12-15	Absent		
Truck Shop	CH 2279004-1					2022-10-20	Absent		
Truck Shop	CH 2276784-1					2022-08-11	Absent		
Truck Shop	CH 2274609-1					2022-06-21	Absent		
Truck Shop	CH 2270782-1					2022-02-03	Absent		

SAMPLING RESULTS FOR SODIUM AND HARDNESS									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Sodium		mg/L		none	none			75	66 - 92
WELL 01 - Raw	CH 2270194-1	mg/L				2022-01-11	68		
WELL 01 - RAW	CH 1777513-1	mg/L				2017-08-31	92		
WELL 02	CH 2270194-2	mg/L				2022-01-11	74		
WELL 03	CH 2270194-3	mg/L				2022-01-11	66		
Hardness		mg/L		none	none			221	210 - 239
WELL 01 - Raw	CH 2270194-1	mg/L				2022-01-11	223		
WELL 01 - RAW	CH 1777513-1	mg/L				2017-08-31	239		
WELL 02	CH 2270194-2	mg/L				2022-01-11	213		
WELL 03	CH 2270194-3	mg/L				2022-01-11	210		

PRIMARY DRINKING WATER STANDARDS (PDWS)									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Arsenic		ug/L		10	0.004			2	ND - 4
WELL 01 - Raw	CH 2275674-1	ug/L				2022-07-14	2		
WELL 01 - RAW	CH 1976385-1	ug/L				2019-07-29	4		
WELL 02	CH 2275674-2	ug/L				2022-07-14	2		
WELL 03	CH 2071678-1	ug/L				2020-03-23	ND		
Fluoride		mg/L		2	1			0.3	0.2 - 0.3
WELL 01 - Raw	CH 2270194-1	mg/L				2022-01-11	0.3		
WELL 01 - RAW	CH 1777513-1	mg/L				2017-08-31	0.3		
WELL 02	CH 2270194-2	mg/L				2022-01-11	0.3		
WELL 03	CH 2270194-3	mg/L				2022-01-11	0.2		
Nitrate as N		mg/L		10	10			0.8	ND - 1.1
WELL 01 - Raw	CH 2275674-1	mg/L				2022-07-14	1		
WELL 01 - Raw	CH 2270194-1	mg/L				2022-01-11	1		
WELL 01 - RAW	CH 2177157-1	mg/L				2021-09-02	0.8		
WELL 02	CH 2275674-2	mg/L				2022-07-14	0.6		
WELL 02	CH 2270194-2	mg/L				2022-01-11	ND		
WELL 03	CH 2271601-1	mg/L				2022-03-10	1.1		
WELL 03	CH 2270194-3	mg/L				2022-01-11	1.1		
Nitrate + Nitrite as N		mg/L		10	10			ND	ND - 0.5
WELL 01 - RAW	CH 1777513-1	mg/L				2017-08-31	0.5		

WELL 02	CH 1777513-2	mg/L				2017-08-31	ND		
Gross Alpha		pCi/L		15	(0)			2.76	1.52 - 3.99
WELL 01 - RAW	CH 1874410-1	pCi/L				2018-06-14	3.99		
WELL 02	CH 1874410-2	pCi/L				2018-06-14	1.52		

SECONDARY DRINKING WATER STANDARDS (SDWS)									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Chloride		mg/L		500	n/a			53	41 - 75
WELL 01 - Raw	CH 2270194-1	mg/L				2022-01-11	47		
WELL 01 - RAW	CH 1777513-1	mg/L				2017-08-31	75		
WELL 02	CH 2270194-2	mg/L				2022-01-11	48		
WELL 03	CH 2270194-3	mg/L				2022-01-11	41		
Iron		ug/L		300	n/a			393	ND - 1210
WELL 01 - Raw	CH 2270194-1	ug/L				2022-01-11	ND		
WELL 01 - RAW	CH 1777513-1	ug/L				2017-08-31	ND		
WELL 02	CH 2270194-2	ug/L				2022-01-11	1210		
WELL 03	CH 2270194-3	ug/L				2022-01-11	360		
Manganese		ug/L		50	n/a			20	ND - 50
WELL 01 - Raw	CH 2270194-1	ug/L				2022-01-11	ND		
WELL 01 - RAW	CH 1777513-1	ug/L				2017-08-31	ND		
WELL 02	CH 2270194-2	ug/L				2022-01-11	50		
WELL 03	CH 2270194-3	ug/L				2022-01-11	30		
Specific Conductance		umhos/cm		1600	n/a			738	665 - 858
WELL 01 - Raw	CH 2270194-1	umhos/cm				2022-01-11	702		
WELL 01 - RAW	CH 1777513-1	umhos/cm				2017-08-31	858		
WELL 02	CH 2270194-2	umhos/cm				2022-01-11	726		
WELL 03	CH 2270194-3	umhos/cm				2022-01-11	665		
Sulfate		mg/L		500	n/a			74.6	65.2 - 93.9
WELL 01 - Raw	CH 2270194-1	mg/L				2022-01-11	69.6		
WELL 01 - RAW	CH 1777513-1	mg/L				2017-08-31	93.9		
WELL 02	CH 2270194-2	mg/L				2022-01-11	69.6		
WELL 03	CH 2270194-3	mg/L				2022-01-11	65.2		
Total Dissolved Solids		mg/L		1000	n/a			453	410 - 520
WELL 01 - Raw	CH 2270194-1	mg/L				2022-01-11	440		
WELL 01 - RAW	CH 1777513-1	mg/L				2017-08-31	520		
WELL 02	CH 2270194-2	mg/L				2022-01-11	440		
WELL 03	CH 2270194-3	mg/L				2022-01-11	410		
Turbidity		NTU		5	n/a			7.7	0.3 - 15.1
WELL 01 - RAW	CH 1777513-1	NTU				2017-08-31	0.3		
WELL 02	CH 1777513-2	NTU				2017-08-31	15.1		

UNREGULATED CONTAMINANTS									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Boron		mg/L		NS	n/a			0.3	0.2 - 0.3
WELL 01 - Raw	CH 2270194-1	mg/L				2022-01-11	0.2		
WELL 01 - RAW	CH 1777513-1	mg/L				2017-08-31	0.3		
WELL 02	CH 2270194-2	mg/L				2022-01-11	0.3		
WELL 03	CH 2270194-3	mg/L				2022-01-11	0.2		
Manganese		ug/L		NS	n/a			27	ND - 50
WELL 01 - Raw	CH 2270194-1	ug/L				2022-01-11	ND		
WELL 02	CH 2270194-2	ug/L				2022-01-11	50		
WELL 03	CH 2270194-3	ug/L				2022-01-11	30		

ADDITIONAL DETECTIONS									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Calcium		mg/L			n/a			46	39 - 48

WELL 01 - Raw	CH 2270194-1	mg/L				2022-01-11	48		
WELL 01 - RAW	CH 1777513-1	mg/L				2017-08-31	48		
WELL 02	CH 2270194-2	mg/L				2022-01-11	39		
WELL 03	CH 2270194-3	mg/L				2022-01-11	48		
Magnesium		mg/L			n/a			26	22 - 29
WELL 01 - Raw	CH 2270194-1	mg/L				2022-01-11	25		
WELL 01 - RAW	CH 1777513-1	mg/L				2017-08-31	29		
WELL 02	CH 2270194-2	mg/L				2022-01-11	28		
WELL 03	CH 2270194-3	mg/L				2022-01-11	22		
pH		units			n/a			7.67	7.4 - 8.1
WELL 01 - Raw	CH 2270194-1	units				2022-01-11	7.5		
WELL 01 - RAW	CH 1777513-1	units				2017-08-31	7.4		
WELL 02	CH 2270194-2	units				2022-01-11	8.1		
WELL 03	CH 2270194-3	units				2022-01-11	7.68		
Alkalinity		mg/L			n/a			228	220 - 240
WELL 01 - Raw	CH 2270194-1	mg/L				2022-01-11	220		
WELL 01 - RAW	CH 1777513-1	mg/L				2017-08-31	240		
WELL 02	CH 2270194-2	mg/L				2022-01-11	230		
WELL 03	CH 2270194-3	mg/L				2022-01-11	220		
Aggressiveness Index					n/a			12.1	11.9 - 12.5
WELL 01 - Raw	CH 2270194-1					2022-01-11	11.9		
WELL 01 - RAW	CH 1777513-1					2017-08-31	11.9		
WELL 02	CH 2270194-2					2022-01-11	12.5		
WELL 03	CH 2270194-3					2022-01-11	12.1		
Langelier Index					n/a			0.21	-0.01 - 0.6
WELL 01 - Raw	CH 2270194-1					2022-01-11	0.06		
WELL 01 - RAW	CH 1777513-1					2017-08-31	-0.01		
WELL 02	CH 2270194-2					2022-01-11	0.6		
WELL 03	CH 2270194-3					2022-01-11	0.2		

[illegible]

The Morning Star Packing Company-DW

CCR Login Linkage - 2022

FGL Code	Lab ID	Date Sampled	Method	Description	Property
CuPb-ss04	CH 2077729-4	2020-09-18	Metals, Total	Breakroom	Cu & Pb Monitoring
Tck Shp	CH 1476624-1	2014-08-28	EPA 552.2	DBPR - RSS Truck Stop	DBP Monitoring
LAB	CH 2272846-2	2022-04-29	Coliform	Laboratory	Water Monitoring
CuPb-ss01	CH 2077729-1	2020-09-18	Metals, Total	Mens Bathroom	Cu & Pb Monitoring
CuPb-ss03	CH 2077729-3	2020-09-18	Metals, Total	Office	Cu & Pb Monitoring
CuPb-ss05	CH 2077729-5	2020-09-18	Metals, Total	QC Lab	Cu & Pb Monitoring
DBPR-ss01	CH 2276785-1	2022-08-11	EPA 552.2	RSS Truck Stop	DBP Monitoring
Bacti-ss01	CH 2270153-1	2022-01-06	Coliform	Shipping	Bacteriological System Monitoring-1
	CH 2271600-1	2022-03-10	Coliform	Shipping	Bacteriological System Monitoring-1
	CH 2272813-1	2022-04-27	Coliform	Shipping	Bacteriological System Monitoring-1
	CH 2273740-1	2022-05-26	Coliform	Shipping	Bacteriological System Monitoring-1
	CH 2275672-1	2022-07-14	Coliform	Shipping	Bacteriological System Monitoring-1
	CH 2277515-1	2022-09-01	Coliform	Shipping	Bacteriological System Monitoring-1
	CH 2279754-1	2022-11-17	Coliform	Shipping	Bacteriological System Monitoring-1
CuPb-ss02	CH 2077729-2	2020-09-18	Metals, Total	Shipping Office	Cu & Pb Monitoring
	CH 2272846-1	2022-04-29	Coliform	Shipping Office	Copper & Lead Monitoring
Bacti-ss02	CH 2270782-1	2022-02-03	Coliform	Truck Shop	Bacteriological System Monitoring-2
	CH 2274609-1	2022-06-21	Coliform	Truck Shop	Bacteriological System Monitoring-2
	CH 2276784-1	2022-08-11	Coliform	Truck Shop	Bacteriological System Monitoring-2
	CH 2279004-1	2022-10-20	Coliform	Truck Shop	Bacteriological System Monitoring-2
	CH 2290288-1	2022-12-15	Coliform	Truck Shop	Bacteriological System Monitoring-2
WELL01	CH 1777513-1	2017-08-31	General Mineral	WELL 01 - RAW	Water Quality Monitoring
	CH 1777513-1	2017-08-31	Wet Chemistry	WELL 01 - RAW	Water Quality Monitoring
	CH 1874410-1	2018-06-14	Radio Chemistry	WELL 01 - RAW	Radio Monitoring
	CH 1976385-1	2019-07-29	Metals, Total	WELL 01 - RAW	Water Quality Monitoring
	CH 2177157-1	2021-09-02	Wet Chemistry	WELL 01 - RAW	Water Quality Monitoring
	CH 2270194-1	2022-01-11	General Mineral	WELL 01 - Raw	MORNING STAR PKG. CO.-WMS.
	CH 2275674-1	2022-07-14	Metals, Total	WELL 01 - Raw	Water Quality Monitoring
	CH 2275674-1	2022-07-14	Wet Chemistry	WELL 01 - Raw	Water Quality Monitoring
WELL02	CH 1777513-2	2017-08-31	General Mineral	WELL 02	Water Quality Monitoring
	CH 1777513-2	2017-08-31	Wet Chemistry	WELL 02	Water Quality Monitoring
	CH 1874410-2	2018-06-14	Radio Chemistry	WELL 02	Radio Monitoring
	CH 2270194-2	2022-01-11	General Mineral	WELL 02	MORNING STAR PKG. CO.-WMS.
	CH 2275674-2	2022-07-14	Wet Chemistry	WELL 02	Water Quality Monitoring
	CH 2275674-2	2022-07-14	Metals, Total	WELL 02	Water Quality Monitoring
0605002-005	CH 2071678-1	2020-03-23	Metals, Total	WELL 03	Well 3 Water Quality Monitoring
	CH 2270194-3	2022-01-11	General Mineral	WELL 03	MORNING STAR PKG. CO.-WMS.
	CH 2271601-1	2022-03-10	Wet Chemistry	WELL 03	Well 3 Water Quality Monitoring